



No. IITMandi(CW)/SE-1541/2023-24/761-62

Dated:01-01-2024

NOTICE INVITING QUOTATION

Sealed item rate quotations as per schedule attached are hereby invited by the undersigned from registered contractors so as to reach in this office on or before **09/01/2024 up to 03:00 PM** and shall be opened on the same day at **03:30 PM** in the O/o Superintending Engineer, IIT Mandi at Kamand South campus in the presence of intending contractors or their authorized representatives.

Name of work: Providing and fixing of outdoor type AMF Panel for 62.5 kVA DG set for providing Power Supply to Nano scale lab A8 building at South Campus of IIT Mandi.

----- As Per Schedule Attached -----

Terms & Conditions:-

1. The work will be carried out as per CPWD General Specifications for **Electrical Works** amended up to date & as per the instructions of the Engineer-in-charge.
2. The work is to be completed within **30 days** from issue of work order.
3. Any damages done during execution of the work/repairs are to be made good by the agency and nothing extra will be paid separately for the same.
4. The Prices quoted should be inclusive of all taxes including GST and nothing extra is to be paid.
5. Agency shall abide by labor rules and regulations.
6. All the applicable taxes shall be deducted from the bill.
7. Compensation of delay of work will be @ 0.05% per day.
8. GST Registration Certificate should also be attached with NIQ.
9. Certificate of authorized services provider for DG sets of reputed makes.
10. All material to be used on the work will have to be got approved from the Engineer-in-charge.

Sd/-
Superintending Engineer

Copy to:-

1. Notice Board.
2. Institute Website

Sd/-
Superintending Engineer

Schedule of Quantity

Name of Work:-Providing and fixing of outdoor type AMF Panel for 62.5 kVA DG set for providing Power Supply to Nano scale lab A8 building at South Campus of IIT Mandi.

Item no.	Description of item	Qty	Unit	Rate(In Rs)		Amount (In Rs)
				(In Figure)	(In Word)	
1	AMF panel for 62.5 kVA DG Set of Kirlosker make, which includes:- Voltage and current measurement and switching components like 3 P LVM, CTs, 100A contactors, replay board, interlocking etc. Panel Protection and control circuit consisting of fuses, MCBs, switches and wiring harness set all fitted inside a power coated panel box. Panel interfaced with DG set will have fetures like protection from overcurrent, overheating, underspeed, overspeed, low lube oil pressure etc.	1	each			
Total						

Note :- 1. Quoted rate should be inclusive of all applicable taxes including GST(nothing extra shall be payable).
2. All Statutory deduction will be made as per prevailing rates.

Sd/-
Superintending Engineer